

PUBLIC HEARING NOTICE
Department of Public Utilities
City of Orangeburg
Pursuant to Section 6-1-330 of the SC Code of Laws

There will be a Public Hearing held on Tuesday, April 18, 2017 at 7:00 P.M. in the City Council Chambers located at 933 Middleton Street in Orangeburg, South Carolina. The purpose of the hearing is to receive public comments on the following:

Adoption of New Electric Rate for the Department of Public Utilities

Citizens are encouraged to attend and present their views, either verbally or in writing. An appointment is not necessary for inclusion on the agenda. Assistance will be provided upon request to accommodate the special needs of handicapped persons attending the meeting. Special assistance requests should be made to the City Administrator's Office at (803) 533-6000 twenty-four (24) hours prior to the scheduled Public Hearing.

The new electric rate will be available for public inspection on and after April 3, 2017, in the Manager's office, DPU, 1016 Russell Street, Orangeburg, South Carolina and may be viewed between 8:00 A.M. and 5:00 P.M., Monday through Friday.

PROPOSED NEW ELECTRIC RATE

Electric Rate – Code 2J – Contract Transmission Service

Applicable:

Service under this rate is available on the DPU Electric system where adequate capacity and suitable voltage is present. The service is available for consumers contracting for a minimum of 20,000 kW who will be served directly from the Department's 115 kV system. Service must be supplied at one point of delivery. A customer elects to receive service on this schedule by signing a Large Power Contract Electric Service Agreement.

Net Monthly Rate

Delivery Demand Charge:

All kW @ \$2.25 per kW of billing or contract demand.

Billing demand shall be the greater of: (a) customer's maximum integrated one hour metered demand during the current month, adjusted for power factor as defined, (b) customer's maximum integrated one-hour metered demand during on-peak periods during the current contract year (12-month period beginning January 1st), or (c) customer's contract demand. The contract demand shall be greater than or equal to 20,000 kW.